

file

PAN # FTX08076AA

TDD #F-6-8808-10



# POTENTIAL HAZARDOUS WASTE SITE IDENTIFICATION

REGION 5 SITE NUMBER TXD000837369

**NOTE:** The initial identification of a potential site or incident should not be interpreted as a finding of illegal activity or confirmation that an actual health or environmental threat exists. All identified sites will be assessed under the EPA's Hazardous Waste Site Enforcement and Response System to determine if a hazardous waste problem actually exists.

<b>A. SITE NAME</b> Webster Generating Sta. (Houston Lighting & Power Co.)		<b>B. STREET (or other identifier)</b> 19301 Old Galveston Rd.	
<b>C. CITY</b> Pasadena	<b>D. STATE</b> TX	<b>E. ZIP CODE</b> 77598	<b>F. COUNTY NAME</b> Harris
<b>G. OWNER/OPERATOR (if known)</b> <b>1. NAME</b> Houston Lighting & Power Co.		<b>2. TELEPHONE NUMBER</b> (713) 922-2195	
<b>H. TYPE OF OWNERSHIP (if known)</b> <input type="checkbox"/> 1. FEDERAL <input type="checkbox"/> 2. STATE <input type="checkbox"/> 3. COUNTY <input type="checkbox"/> 4. MUNICIPAL <input checked="" type="checkbox"/> 5. PRIVATE <input type="checkbox"/> 6. UNKNOWN			
<b>I. SITE DESCRIPTION</b> <p>The site is a 607-acre electrical generating station with several surface impoundments, a storage tank, and a container storage area. This plant has been in operation since 1965.</p> <p>Lat. 29° 31' 47" N Long. 95° 06' 10" W</p>			
<b>J. HOW IDENTIFIED (i.e., citizen's complaint, OSHA citations, etc.)</b> Environmental Priorities Initiative		<b>K. DATE IDENTIFIED (mo., day, &amp; yr.)</b> 9-8-88	
<b>L. SUMMARY OF POTENTIAL OR KNOWN PROBLEM</b> <p>The main areas of concern are two surface impoundments. One is known as a "demineralizer regenerant boiler blowdown impoundment", and the other is an "inorganic metal cleaning impoundment". Both were constructed with a 3 foot compacted clay liner. These ponds, along with the container storage area were closed with approved closure plans. A third surface impoundment contains ammoniated citric acid, but is not required to be permitted. A potential hazard exists from possible seepage from one or more of the impoundments before the contamination was removed.</p>			
<div style="text-align: right;"><b>90068264</b> </div>			
<b>M. PREPARER INFORMATION</b> <b>1. NAME</b> James Hussey		<b>2. TELEPHONE NUMBER</b> (214) 744-1641	<b>3. DATE (mo., day, &amp; yr.)</b> 9-8-88